

CERTIFICATE OF COMPLIANCE

Certificate Number 20160518-E478065
Report Reference E478065-20160518
Issue Date 2016-MAY-18

Issued to: GSTECH
5 Saeugae 4-gil
Siheung-si Gyeonggi-do 429-872 KOREA

This is to certify that representative samples of **EMERGENCY LIGHTING EQUIPMENT FOR USE IN HAZARDOUS LOCATIONS**
Emergency Lighting Equipment for use in Hazardous (Classified) Locations, Class I, Division 2, Groups A, B, C and D.

Emergency Luminaire Sign: G1-PMEN-; followed by M01, M02, M03, M04, M05, M06, M07, M08 or M17.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 844, Luminaires for Use in Hazardous (Classified) Locations
UL 924, Emergency Lighting and Power Equipment
ISA-12.12.01, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

